

# MUNICIPAL CORPORATION JALANDHAR

WATER TESTING LABORATORY  
(WATER ANALYSIS REPORT)

REF. NO: -666

REF. DATE: -06 /04/26

Sample provided by:- Cambridge International School, Chotti Baradari part 2 Jalandhar

SR.NO	TEST	REQUIRED LIMIT IS10500	SAMPLE
1	COLOUR	5 Hazen	Colorless
2	ODOUR	Unobjectionable	Normal
3	TASTE	Agreeable	normal
4	PH	6.5 - 8.5	6.7
5	DISSOLVED SOLIDS (TDS)	500 ppm	145
6	TOTAL HARDNESS (as CaCO <sub>3</sub> )	300 mg/l	98
7	ALKALINITY	200 mg/l	86
8	CALCIUM (as Ca <sup>++</sup> )	75 mg/l	9.4
9	IRON	0.3 mg/l	0.1
10	CHLORIDE	250 mg/l	26
11	SULPHATES	150 mg/l	nil
12	NITRATES	4.5 mg/l	nil
13	FLOURIDE	1.0 mg/l	o.1
14	RESIDUAL CHLORINE	0.2 mg/l	nil
15	TOTAL COLLIFORM COUNT (by MPN method per 100ml)	NIL	nil

REMARKS :-

provided water sample found satisfactory as per the applied tests



DATE:-09/04/26

*Neelam Kaur*  
Analyst  
Municipal Corporation Jalandhar  
ANALYST